



## **ADDENDUM #1**

### **Mosquito Hill Nature Center: Roof Repairs**

To All Bidders:

Identified below are clarifications and additions to the original RFB and are hereby made part of the bid documents as fully and completely as if the same were fully set forth therein.

- **Metal Fascia Additions/Changes**

Repair up to 900 LF of rotted sub fascia (versus 450 LF).

The new fascia shall be commercial grade.

The new fascia shall match existing colors of the building.

- **Gutter Apron Alternate**

The removal of the Decra shingle may not be possible. Alternate #1 shall be the price (deduct or addition to base bid) to eliminate removal, slide flashing under bottom row of Decra shingles, and secure properly after replacement of rotted or damaged sub fascia. This removes the ice and water membrane.

Bidders must use the revised bid form (2<sup>nd</sup> page of this Addendum) Failure to do so, will result in the rejection of your bid.

Issued:

April 14, 2025

Nicole Schoultz, Procurement Coordinator

**OUTAGAMIE COUNTY BID FORM**  
**Mosquito Hill Nature Center Roof Repairs**

**Bid Dues:** April 16, 2025- 1:00 p.m. CT

**Deliver Bids To:** Outagamie County  
Attn: Nicole Schoultz, Purchasing  
320 S Walnut St  
Appleton, WI 54911

*If hand delivering, see note in Section 10.0*

Lump Sum Bid \$ \_\_\_\_\_

Written Amount \_\_\_\_\_ Dollars and \_\_\_\_\_ Cents

Alternate #1 \$ \_\_\_\_\_

Check One  Addition to Base Bid  Deduction from Base Bid

**Include: Completed Attachment A and References**

**Acknowledgement of Addendum**

Addendum: 1 Date Issued: April 14, 2025

Firm Name: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_

Print name: \_\_\_\_\_

Title/Date: \_\_\_\_\_

Address: \_\_\_\_\_

Telephone: \_\_\_\_\_

E-mail: \_\_\_\_\_