

15 Billie Potter Court

1500 North Lincoln Avenue

Appleton, WI 54911

608.724.2341

Potter Lawson

ARCHITECTS

Meyer Associates Incorporated

278 Park Avenue, P.O. Box 250

Gilsum, Illinois 60025 312.855.1234

Meyer Associates Incorporated

190 East College Avenue

Appleton, Wisconsin 54911

608.724.2341

ARNOLD & O'SHEA, INC.

CONSULTING ENGINEERS

210 FORWARD DRIVE

WATKINS, WISCONSIN 54981

608.724.2341

ARNOLD & O'SHEA, INC.

CONSULTING ENGINEERS

210 FORWARD DRIVE

WATKINS, WISCONSIN 54981

608.724.2341

REFLECTED CEILING PLAN KEY

RECESSED FLUORESCENT FIXTURE

RECESSED FLUORESCENT FIXTURE

RECESSED FLUORESCENT FIXTURE

RECESSED "CAN" FIXTURE

SURFACE MOUNTED EXIT FIXTURE

SURFACE MOUNTED OR SUSPENDED FLUORESCENT FIXTURE

SURFACE MOUNTED OR SUSPENDED FLUORESCENT FIXTURE

SURFACE MOUNTED OR SUSPENDED FLUORESCENT FIXTURE

LINEAR DEFUSER

INAC GRILLE (SIZE VARIES)

NON-SECURITY ACCESS PANEL (SIZE VARIES)

SECURITY ACCESS PANEL (SIZE VARIES)

1/2" DEEP INTERSTITIAL SPRINKLER

2'X2' SUSPENDED CEILING

2'X4' SUSPENDED CEILING

SECURITY CEILING

PLASTER CEILING

GAB CEILING

R.C.P. NOTES:

VERIFY ALL FINISHES, COLORS, PATTERNS, QUANTITIES, DIMENSIONS, & SIZES IN FIELD.

1. ALL ACCESS PANELS ARE 24" X 24" UNLESS NOTED.

2. SECURITY CEILING PANELS ARE 8'-4" AFF. AND 13'-6" AFF. SET DETAIL 19/5/31.

3. PLASTER CEILING IS 8'-0" AFF. AND SECURITY CEILING IS 11'-4" AFF. - SEE DETAIL 19/5/32.

4. UNLESS NOTED, SECURITY CEILING TO LINE UP WITH CEILING TO EXPOSED DECK (V) / STEEL ANGLE.

Date	Issuance / Revisions	Symbol
2-21-91	FINISH FOR FMS	
2-23-91	NOTED INTERSTITIAL SPRKLS	
2-28-91	ISSUED FOR APPROVAL	
3/1/91	ISSUED FOR BIDDING - PHASE 2	

APPLETON, WISCONSIN

OUTAGAMIE COUNTY

JUSTICE CENTER

Project No.	Review Agency	Date:
1544	I. S. O. N.	12-11-90
Drawn By	Check By	PP-5
OLSON	OLSON	

PRINAPAL SPRINKLERS IN CENTER SECTION THIS PLAN INDICATES PROTECTING MEZZANINE SPACE JUST BELOW 5TH FLOOR DECK.

ALL HANGERS (7-5) UNLESS NOTED FOR CELL PANEL.
ALL INTERSTITIAL LINE HANGERS (7-7) UNLESS NOTED.
ALL INTERSTITIAL MAIN HANGERS (7-25) UNLESS NOTED.

RECORD DRAWING
Date 11/20/92
United States
Fire Protection

LOWER LEVEL
FOURTH FLR.
SCALE 1/8" = 1'-0"

CELL CHASE - DETAIL A
SCALE: 3/8" = 1'-0"

SPRINKLER TYPE	105	212	286	FINISH	TOTAL
1/2" INTERSTITIAL SPRKLS				128	128
1/2" UPGRADE	96			BRASS	96
					224
					224

UNITED STATES FIRE PROTECTION
17750 W. LIBERTY LA. NEW BERLIN, W. 53446
(414) 782-3311