

ADDENDUM NO. TWO

DATE: May 14, 2021
TO: ALL PLAN HOLDERS
FROM: Peggy Hawley, Westwood
SUBJECT: Appleton International Airport
Parking Lot Improvements

This addendum forms a part of the contract documents and modifies the original proposal documents.

Acknowledge receipt of this Addendum on the Bid Form. Failure to do so may result in the rejection of your bid.

Changes to Bid Form:

Base Bid

Add the following item:
655.0620 Electrical Wire Lighting 8 AWG
655.0630 Electrical Wire Lighting 4 AWG

Alternative 2

Remove the following:
655.0620 Electrical Wire Lighting 8 AWG

Changes to the Special Provisions:

Revise Item 19. Precast Concrete Wheel Stops as follows:

Remove section B.3 Mounting Hardware
Remove the third sentence of C. Construction.

Add Item 36. Conduit Special 2-Inch

36. Conduit Special 2-Inch.

Revise subsection 652.3.1.1(1) with the following:

All conduit special shall be Schedule 40 PVC.

Changes to the Plans:

Replace sheets 2 and 4.